



Confirmation

eurofins

Eurofins Product Testing A/S confirms that a sample of a rubber floor adhesive with the name

Uzin KE 66
supplied by
Uzin Utz AG

showed low VOC contents in a test in accordance with SCAQMD rule 1168, as specified in LEED credit IEQ 4.1 (adhesives and sealants).

VOC contents was below the limit value specified as 60 grams VOC minus water per liters for rubber floor adhesives.

The test has been performed in October 2009, see test report no. 770904_1168.

Volatiles content (incl. water) was calculated by Eurofins.

Water content was determined by Eurofins.

Solids content was determined by Eurofins.

With this confirmation, use of product Uzin KE 66 may qualify for fulfillment of LEED credit IEQ 4.1 (adhesives and sealants).

16 October 2009

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com